



**Mount Diablo Unified School District  
RFI & PCO Summary  
No. 1612 Electrical Upgrades for Technology**

RFI #	Description	Site	Status	PCO #	PCO Amount	Remarks
1	Allow B-Line Roof Blocks	CHS/CVHS	Approved	n/a	\$ -	
2	Mount Bldg E IDF Next to Existing	CPHS	Approved	n/a	\$ -	
3	Woodshop Remodel - Wiremold	MDHS	Approved	MDHS-1	\$ 1,344.00	
4	Use Existing Northgate Roof Strut	NHS	Approved	n/a	\$ -	DSA Approved
5	Relocate Art Room IDF & Change Circuit ID	NHS	Approved	n/a	\$ -	Using Panel 2L Circuit 36
6	Relocate 914 IDF. Change Rm 701 Circuit ID	NHS	Approved	n/a	\$ -	Using Panel 7L1 Circuits 28/30
7	Relocate 301/501 IDFs. Utilize 2nd Panel in MDF	CVHS	Approved	CVHS-1	\$ 4,982.00	Using Panel 8L3 Circuits 17/19, 21. 12AWG ok
8	Relocate IDF from Room 504 to 509	YVHS	Approved	YVHS-1	\$ 2,188.00	Add to extend circuit to Room 509
9	Panel Names, 500-Wing Wiremold Issues	Riverview	Approved	RVMS-1	\$ 522.00	PCO to Cover Added Carpentry Work
10	Relocate ALL IDF Cabinets	Foothill	Approved	n/a		
11	Relocate IDF Cabinets to Different Walls	Diablo View	Approved	n/a		
PCO Total					\$ 9,036.00	